



**NOTE**

- 1) VERIFY HEATER VOLTAGE PRIOR TO CONNECTING TO POWER SOURCE.
- 2) POWER SOURCE AC SUPPLY 230VAC +5%/-10%, 115VAC +5%/-10%

CONTROLLED DRAWING

This is a registered part with FM/UL for use on an approved/ listed fire pump driver. No substitutions are allowed. Consult engineering prior to and regarding any change.

F	THERMOSTAT WAS 120 ON 140 OFF	RJT	KJK	01OCT10
E	ADDED OPTIONAL LUBE OIL HEATER	ASC	KJK	11MAR08
D	REVISED INTERCONNECTIONS	KJK	JTW	06DEC99
SYM	REVISION	ENGR	APVD	DATE

THIS DRAWING AND THE INFORMATION HEREON ARE OUR PROPERTY AND MAY BE USED BY OTHERS ONLY AS AUTHORIZED BY US. UNPUBLISHED--ALL RIGHTS RESERVED UNDER THE COPYRIGHT LAWS.	DWN	DMPOTTER
	DATE	01MAR94
	ENGR	JTWHITNEY
UNLESS OTHERWISE SPECIFIED TOLERANCES ARE:	CHK	
DECIMAL		
.X	±1.5	±0.06
.XX	±0.8	±0.03
.XXX	±0.25	±0.01
FRACTIONAL		
ANGULAR	±1/32	
	±.5°	
USAGE: 1000 SERIES	INSP Y	SERIES CODE MP

# CLARKE

**Fire Protection Products, Inc.**

NAME		WIRING DIAGRAM, KIM JACKET WATER HEATER	
		120/240VAC - 1500 WATTS	
SIZE	PART NO.	REV	
A	C07591	F	
SCALE	UNITS	SHEET	OF
NONE	NONE	1	1